

Rainwater Harvesting for Military Installations – The Time is Now


Environment, Energy & Sustainability Symposium
Denver, CO
14-17 June 2010

Richard J. Scholze
U.S. Army Corps of Engineers

Construction Engineering Research Laboratory (CERL)
Champaign, IL

Jeannette Fiess
U.S. Army Corps of Engineers
Seattle District

Special Thanks to Malcolm McLeod
U.S. Army Corps of Engineers
Headquarters




**US Army Corps
of Engineers®**

Engineer Research and Development Center

Report Documentation Page				Form Approved OMB No. 0704-0188	
Public reporting burden for the collection of information is estimated to average 1 hour per response, including the time for reviewing instructions, searching existing data sources, gathering and maintaining the data needed, and completing and reviewing the collection of information. Send comments regarding this burden estimate or any other aspect of this collection of information, including suggestions for reducing this burden, to Washington Headquarters Services, Directorate for Information Operations and Reports, 1215 Jefferson Davis Highway, Suite 1204, Arlington VA 22202-4302. Respondents should be aware that notwithstanding any other provision of law, no person shall be subject to a penalty for failing to comply with a collection of information if it does not display a currently valid OMB control number.					
1. REPORT DATE JUN 2010		2. REPORT TYPE		3. DATES COVERED 00-00-2010 to 00-00-2010	
4. TITLE AND SUBTITLE Rainwater Harvesting for Military Installations -The Time is Now				5a. CONTRACT NUMBER	
				5b. GRANT NUMBER	
				5c. PROGRAM ELEMENT NUMBER	
6. AUTHOR(S)				5d. PROJECT NUMBER	
				5e. TASK NUMBER	
				5f. WORK UNIT NUMBER	
7. PERFORMING ORGANIZATION NAME(S) AND ADDRESS(ES) Army Engineer Research and Development Center,Construction Engineering Research Laboratory,Champaign,IL,61826-9005				8. PERFORMING ORGANIZATION REPORT NUMBER	
9. SPONSORING/MONITORING AGENCY NAME(S) AND ADDRESS(ES)				10. SPONSOR/MONITOR'S ACRONYM(S)	
				11. SPONSOR/MONITOR'S REPORT NUMBER(S)	
12. DISTRIBUTION/AVAILABILITY STATEMENT Approved for public release; distribution unlimited					
13. SUPPLEMENTARY NOTES Presented at the NDIA Environment, Energy Security & Sustainability (E2S2) Symposium & Exhibition held 14-17 June 2010 in Denver, CO.					
14. ABSTRACT					
15. SUBJECT TERMS					
16. SECURITY CLASSIFICATION OF:			17. LIMITATION OF ABSTRACT Same as Report (SAR)	18. NUMBER OF PAGES 53	19a. NAME OF RESPONSIBLE PERSON
a. REPORT unclassified	b. ABSTRACT unclassified	c. THIS PAGE unclassified			


Water Thoughts

- **“Water is the oil of the 21st Century.” Andrew Liveris, CEO, Dow, 2008**
- **Half the world does not have access to an adequate, safe water supply**
- **The ultimate source of all of our fresh water is precipitation**
- **8% of all energy use in the USA is directly related to pumping, treating or heating water – Clark Reed, USEPA**
- **The cheapest water you will ever have is the water you already have.**
- **Equivalent of green energy**
 - Utility costs - \$2.00 to \$5.00 per gallon day of capacity to build water or wastewater treatment plant
 - New supplies costly and rising
 - Consumer costs – water and sewer combined between 0.5 and 1.0 cent per gallon




What Are PWTBs?

- **Introducing: Rainwater Harvesting for Army Installations PWTB 200-1-75**
- **Public Works Technical Bulletins**
- **Sponsored by USACE HQ**
- **Variety of subjects**
- **Available through Whole Building Design Guide**
- **Accessible at:**
 - http://www.wbdg.org/ccb/browse_cat.php?o=31&c=215
- **May have to use alternate path – CCB, Army/COE, then PWTB**




PWTB Contents


- **History of Rainwater Harvesting**
- **Overview**
- **Drivers, Opportunities and Regulations**
- **Developing a Rainwater Harvesting System**
- **Types of Systems**
- **Operation and Maintenance**
- **Potential Military Installation Applications**
- **Lessons Learned**
- **Summary**



History

- **Not a new idea**
- **Long history in the U.S. and the world**
- **Catchment structure evidence dates back to third millennium B.C.**
- **Negev Desert, Greece, Italy, Egypt, Turkey, Mexico**
- **In U.S. – Historic evidence in Texas and Arizona**
 - **First - Water source for residents, then stopping points for travelers, commerce centers**
- **Recently, Germany a technology leader**
- **Common in rural areas**





US Army Corps
of Engineers®

Engineer Research and Development Center

Military Installation Water Drivers

Water Resources


- Increasing Water Quantity and Quality Concerns
- Drought
- Climate Change

Legislative and Executive Drivers

- Clean Water Act
- Energy Policy Acts
- Executive Order 13514
- EISA Section 438

Defense/Army Strategies and Policies

- Strategic Plan for Army Sustainability
- Army Strategy for the Environment
- 2005 Army Energy and Campaign Plan for Installations
- 2010 IMCOM Campaign Plan
- Installation Sustainability Plans - Water Conservation Goals
- LEED (Leadership in Energy and Environmental Design)
USGBC
- Green Building Initiative
- Federal Best Management Practices




Decreasing Supply

- Over Withdrawal
- Climate Change
- Cost and Financing
- Quality Degradation

"I wish to make it clear to you, there is not sufficient water to irrigate all the lands which could be irrigated, and only a small portion can be irrigated. I tell you, gentlemen, you are piling up a heritage of conflict."

-- Maj. John Wesley Powell, 1893

Lynn Betts, NRCS




US Army Corps
of Engineers®

Engineer Research and Development Center

FEMP Best Management Practices


- 1. Water Management Planning**
- 2. Information and Education Programs**
- 3. Distribution System Audits, Leak Detection and Repair**
- 4. Water Efficient Landscaping**
- 5. Water Efficient Irrigation**
- 6. Toilets and Urinals**
- 7. Faucets and Showerheads**
- 8. Boiler/Steam Systems**
- 9. Single-Pass Cooling Equipment**
- 10. Cooling Tower Management**
- 11. Commercial Kitchen Management**
- 12. Laboratory/Medical equipment**
- 13. Other Water Use**
- 14. Alternate Water Sources**



Other Water Use/Alternate Water Sources Options

*What can be done to increase available supply?
How can we efficiently use what's available?*

- Water Reuse
- Desalination
- Produced Water
- **RAINWATER HARVESTING**
- Ground Water Recharge
- Graywater Reuse
- Sewer Mining



Rainwater Harvesting

Ideal for nearly any large building

Also applicable to expansive parking lots


Water stored in tanks or ponds – reducing runoff

Stored water can be used indoors – filtered and treated – fixture flushing, laundry, cooling tower, boiler makeup

Outdoors – irrigation, water features

Some areas – potable water source

Result – reduces overall demand for municipal water



Why Rainwater Harvesting?

Climate change

Water shortages – Augment supply

Save resources

Maintain local control

Insure reliability of supply

Mitigate flooding

Reduce erosion

Reduce hydraulic loading


Requires little energy input

Excellent water quality


**LEED points – percent water savings, storm water reduction,
reduction of sewage from potable water**

**Most water used on installations does not have to be of drinking
water quality.**


**Beneficially use water which would normally be discarded as
stormwater**



Rainwater Harvesting System



- 1 First flush fine filter
- 2 Calming inlet
- 3 Floating filter
- 4 Overflow




US Army Corps
of Engineers®

From: VA Rainwater Harvesting Manual

Engineer Research and Development Center


Standards

- **No national standards**
- **Plumbing Codes Changing - Currently UPC and IPC do not directly address rainwater harvesting in potable or stormwater sections causing confusion**
- **Definitions – UPC**
- **Harvested rainwater – Conveyed from a building roof, stored in a cistern and disinfected and filtered before being used for toilet flushing, can also be used for landscape irrigation**
- **States and local jurisdictions have developed standards or guidelines**
- **Ex. Texas – State promotes for any use Including potable provided appropriate treatment**
- **Portland, OR – Use for nonpotable applications**
- **Draft guidelines suggested by American Rainwater Catchment Systems Association**
- **Many states and municipalities established or establishing rules – OH, KY, HI, AZ, NM, WA, WV, TX and others**
- **Rules, ordinances, building codes etc. run gamut from requiring RWH systems in new construction to prohibiting tanks as an eyesore**



Development of An Active Rainwater Harvesting System

- **Questions to Be Answered**
 - Retrofit to an existing building or a new integral system?
 - System size - L,M,S?
 - How complex – “Active” or “Passive”?
 - Permissible costs?
 - System requirements - Intensity of use, level of commitment, water security?
 - Intended use of the system? Irrigation, potable, other?
 - What water quality is required?



Water Balance Analysis

Allows designer to determine how much rainwater can be collected.


Provides a supply and demand analysis on a monthly or quarterly basis

Examine variables of rainfall and water demand

Determine cistern capacity – Is backup potable available or not?

Theory – 1 inch of rain on 1000 square feet of nonpermeable surface provides 620 gallons

Estimate demand




Candidate Buildings and Locations

Best candidates

Simplest Collection Point – Roof

Ex. Low to Mid-rise Buildings Best Ratio: Roof Area to Toilets

However, Nearly Any Building Can be Used




**US Army Corps
of Engineers®**

Engineer Research and Development Center


Components of a Rainwater Harvesting System

Catchment Surface/Collection Area
Conveyance
Roof Washer (Prefiltration)
Primary Settling Tank
Storage
Distribution
Purification
Screens, Debris Excluders, Etc.



Figures from VA Rainwater Harvesting Manual

Calming Inlet



Components

Roofing Materials

Metal

Clay/Concrete Tile

Shingles

Slate

Wood, Tar or Gravel



Siphonic filter




Downspout filter



Old and Modern Filter Designs

Images from VA Rainwater Harvesting Manual



**US Army Corps
of Engineers®**

Engineer Research and Development Center

Components (Cont.)

Gutters and Downspouts


- Careful of metals, if potable use
- Most common – PVC, vinyl, pipe, aluminum, steel
- Ensure adequate pitch
- Modern filters extremely low maintenance and cleaning
- Filters should be self-cleaning and self-drying between events
- Use stable materials which will not change shape and can withstand temperature changes, e.g. stainless steel is best

Leaf screens – variety available, must be maintained

First-flush diverters – routes first flush flow away from storage tanks


Roof washers – just before storage tank, filter small debris

- Modern versions require little maintenance







Disinfection array with pump, filters and UV lamp



First Flush Diverter



Box Roof Washer



Components (Cont.)

Storage Tank or Cisterns

Heart of system and most expensive component

Above or below ground


Epoxy steel, fiberglass, concrete, polyethylene, or other materials


Must be opaque, covered, vents screened

Potable tanks must have accessibility

Locate near to supply and demand points

Provide proper seating





US Army Corps
of Engineers®

Engineer Research and Development Center

Components (Cont.)

Pumps, Filters, Treatment, Valves, Piping and Controls

Distribute harvested rainwater from storage tank to designated end use

Filtering and disinfection prior to delivery


Control valves monitor level of rainwater versus pump operation

Many municipalities require piping to toilets, urinals, irrigation systems and hose bibs be continuously labeled with “Harvested rainwater, do not drink”

Usually a pump and pressure tank between water storage and treatment and the end use


On-demand pumps eliminate need for a pressure tank, an all-in-one unit

Disinfection, usually UV or chlorination, for potable use, any military application for potable should consult Public Health Command




Economics


- **Varies considerably with the application**
- **- Often \$1 per gallon of storage capacity**
- **Paybacks variable – often 10 to 15 years**
- **One school in TX had 5-year payback for irrigation use.**



Military Experience

- **Army Experience**
- **Limited in CONUS, HI and Guam have potable collection facilities**
- **Buildings have been designed with focus on nonpotable applications**






Kilauea Military Camp, Hawaii

**US Army Corps
of Engineers®**

Engineer Research and Development Center

Army Example Joint Base Lewis –McChord Company Building



US Army Corps
of Engineers®

Engineer Research and Development Center


Rainwater Vault Sizing

- **Review occupancy**
 - High use after morning PT
 - Standard office use during day
 - 80% male, 20% female
 - Indicated 107.2 gallons/day usage
 - 10,107 gallons/month storage required
- **Review water availability**
 - Lowest monthly rainfall is 0.78 inches (August)
 - With roof area this amounts to 50.57 m³
- **Size the vault**
 - Vault sized to hold 2 months' water to account for dry months
 - **Standard vault sized at 84 m³**




Rainwater Retention Vaults

- 22,000 gallon precast concrete vault
- Roof runoff directed to vault
- Non-potable pumped into buildings and used to flush toilets




Retention Vault Lessons Learned

- **Non-potable water isn't metered**
- **Consider filter design**
 - Toilets were getting stained
- **Review industry standards and design recommendations**
- **Education**
- **Flush out system prior to turn over**




Military Experience

- **Air Force Guidance approves for irrigation and fixture flushing**
- **Portions of Guidance**
 - Cross-connection testing
 - Identify piping as nonpotable
 - Monthly inspections of systems
 - Fixture flushing water must be filtered and disinfected
 - Makeup provisions in case of drought
 - Appropriate consultation with DPW/Bioenvironmental
 - Labeling of toilets and buildings




Military Experience

- **Lessons learned**
- **During design phases increase coordination between all engineering disciplines and improve technical drawings.**
- **Essential for design team to have familiarity with rainwater detention technologies.**
- **O&M staff need thorough training**
- **Buy-in is essential between designers and construction and O&M staff to be aware of water reduction goals of the project and be committed.**
- **Thoroughly review early construction documents to avoid change orders**
- **Require rainwater harvesting at the Request for Proposal level and emphasize life cycle costs over first costs**




UT School of Nursing



US Army Corps
of Engineers®


Engineer Research and Development Center

Rainwater from Roof



US Army Corps
of Engineers®

Engineer Research and Development Center



**US Army Corps
of Engineers®**



Engineer Research and Development Center



US Army Corps
of Engineers®

Engineer Research and Development Center


Mitchell Physics



US Army Corps
of Engineers®

Engineer Research and Development Center

Rain Tank



US Army Corps
of Engineers®


Engineer Research and Development Center



**US Army Corps
of Engineers®**

Engineer Research and Development Center


Pump Enclosure



US Army Corps
of Engineers®

Engineer Research and Development Center

30 GPM Pump



US Army Corps
of Engineers®

Engineer Research and Development Center

RWH Systems for Livestock and Wildlife




Figure 1. A typical rainwater harvesting system uses a roof, gutters, downspout and pipes underground, and backup into the top of the collection tank. This prevents livestock from damaging the pipes and allows the tank to be much further away from the shed. Unless there is a drain along the lower pipe, the standing pipes will contain water that is susceptible to freezing.

From: Texas Cooperative Extension TAMU






Figure 2. This rainwater harvesting system uses a prepared surface of concrete, rock or a sealing material to shed the rainfall. The rainwater is then diverted into the top of the collection tank.






Rainwater “guzzlers” at Big Bend State Park in far West Texas are used to provide water for wildlife.



**US Army Corps
of Engineers®**

Engineer Research and Development Center

Using Landscape as a Rain Harvesting System




**US Army Corps
of Engineers®**

Engineer Research and Development Center

Landscape Design Concepts

- Soil preparation and depth
- Shape land to hold water
- Chose appropriate plant material
- Proper irrigation system design
- Capture on-site sources of water
- Symbiosis between landscape and stormwater control
- ***KEEP IT WHERE IT FALLS***




Shape land to hold water



US Army Corps
of Engineers®

Engineer Research and Development Center





US Army Corps
of Engineers®

Engineer Research and Development Center

Future and Larger Scale Systems

- **More complex operations**
- **Collect large quantities**
- **Blocks and large buildings have dual plumbing and communal systems with treatment**
- **Combine with other sources such as graywater, condensate and infiltrating groundwater**






**US Army Corps
of Engineers®**

Engineer Research and Development Center

Summary

- Numerous drivers promote water efficiency
- Rainwater harvesting – one option to using less potable water
- Quantities can be significant
- Regulations changing
- Widely used in many states
- Match water quality with end use
- Treatment processes variable
- U.S. Playing Catch-up
- New/emerging technologies should be demonstrated/adopted
- Demonstrated on Federal facilities
- Spell out requirements in contracting documents for new construction
- PWTB available now




Questions, Comments?

Contact information or for additional information or resources

Richard.J.Scholze@usace.army.mil


217-398-5590

Thanks also to Bill Hoffman and Dan Pope for selected images



**US Army Corps
of Engineers®**

Engineer Research and Development Center



US Army Corps
of Engineers®

Engineer Research and Development Center